



BID

2013 Drainage Improvements

East Ponce de Leon Ave. and Rogers St.

ADDENDUM

Addendum #3:

Date: June 24th, 2013

Description: The following change shall be made to Sheet #4 of the “*Construction Plans for City of Clarkston, GA – Drainage Structure Improvements*”:

Sheet 4 - Junction Box at Station 1+10 of Storm Sewer.

Contractor shall keep 3 feet of undisturbed dirt between the junction box excavation at the power pole.

Contractor shall call Earl Towns with Georgia Power at 770 322 5818 seven days before excavating in power pole area.